

0631-216  
**ELEVATION CERTIFICATE**

OMB No. 1660-0008  
Expires March 31, 2012

Important: Read the instructions on pages 1-9.

**SECTION A - PROPERTY INFORMATION**

A1. Building Owner's Name: R. J. REYNOLDS CONSTRUCTION, LLC  
 A2. Building Street Address (including Apt., Unit, Suite, and/or Bldg. No.) or P.O. Route and Box No.: 223 VICTOR'S COURT  
 City: Richmond Hill State: GA. ZIP Code: 31324  
 A3. Property Description (Lot and Block Numbers, Tax Parcel Number, Legal Description, etc.): LOT 395, TRANQUILLA HALL, PHASE 3, BUCKHEAD, PHASE 9 - C  
 A4. Building Use (e.g., Residential, Non-Residential, Addition, Accessory, etc.): RESIDENTIAL  
 A5. Latitude/Longitude: Lat N 31.84698 Long. W 081.25835 Horizontal Datum:  NAD 1927  NAD 1983  
 A6. Attach at least 2 photographs of the building if the Certificate is being used to obtain flood insurance.  
 A7. Building Diagram Number: 1B  
 A8. For a building with a crawlspace or enclosure(s):  
 a) Square footage of crawlspace or enclosure(s): NA sq ft  
 b) No. of permanent flood openings in the crawlspace or enclosure(s) within 1.0 foot above adjacent grade: NA  
 c) Total net area of flood openings in A8.b: NA sq in  
 d) Engineered flood openings?  Yes  No  
 A9. For a building with an attached garage:  
 a) Square footage of attached garage: 532 sq ft  
 b) No. of permanent flood openings in the attached garage within 1.0 foot above adjacent grade: 0  
 c) Total net area of flood openings in A9.b: 0 sq in  
 d) Engineered flood openings?  Yes  No

**SECTION B - FLOOD INSURANCE RATE MAP (FIRM) INFORMATION**

B1. NFIP Community Name & Community Number: BRYAN COUNTY 130016  
 B2. County Name: BRYAN  
 B3. State: GA.  
 B4. Map/Panel Number: 13029C0375  
 B5. Suffix: C  
 B6. FIRM Index Date: 3-2-09  
 B7. FIRM Panel Effective/Revised Date: 3-2-09  
 B8. Flood Zone(s): AE  
 B9. Base Flood Elevation(s) (Zone AO, use base flood depth): 12  
 B10. Indicate the source of the Base Flood Elevation (BFE) data or base flood depth entered in Item B9.  
 FIS Profile  FIRM  Community Determined  Other (Describe)  
 B11. Indicate elevation datum used for BFE in Item B9:  NGVD 1929  NAVD 1988  Other (Describe)  
 B12. Is the building located in a Coastal Barrier Resources System (CBRS) area or Otherwise Protected Area (OPA)?  
 Designation Date:  CBRS  OPA  Yes  No

**SECTION C - BUILDING ELEVATION INFORMATION (SURVEY REQUIRED)**


C1. Building elevations are based on:  Construction Drawings\*  Building Under Construction\*  Finished Construction  
 \*A new Elevation Certificate will be required when construction of the building is complete.  
 C2. Elevations - Zones A1-A30, AE, AH, A (with BFE), VE, V1-V30, V (with BFE), AR, AR/A, AR/AE, AR/A1-A30, AR/AH, AR/AO. Complete items C2.a-h below according to the building diagram specified in item A7. Use the same datum as the BFE.  
 Benchmark Utilized: EGPS NETWORK Vertical Datum: NAVD 88  
 Conversion/Comments: NA  
 Check the measurement used:  
 a) Top of bottom floor (including basement, crawlspace, or enclosure floor): 15.64 feet  meters (Puerto Rico only)  
 b) Top of the next higher floor: NA feet  meters (Puerto Rico only)  
 c) Bottom of the lowest horizontal structural member (V Zones only): NA feet  meters (Puerto Rico only)  
 d) Attached garage (top of slab): 14.9 feet  meters (Puerto Rico only)  
 e) Lowest elevation of machinery or equipment servicing the building (Describe type of equipment and location in Comments): NA feet  meters (Puerto Rico only)  
 f) Lowest adjacent (finished) grade next to building (LAG): 12.34 feet  meters (Puerto Rico only)  
 g) Highest adjacent (finished) grade next to building (HAG): 13.64 feet  meters (Puerto Rico only)  
 h) Lowest adjacent grade at lowest elevation of deck or stairs, including structural support: NA feet  meters (Puerto Rico only)

**SECTION D - SURVEYOR, ENGINEER, OR ARCHITECT CERTIFICATION**

This certification is to be signed and sealed by a land surveyor, engineer, or architect authorized by law to certify elevation information. I certify that the information on this Certificate represents my best efforts to interpret the data available. I understand that any false statement may be punishable by fine or imprisonment under 18 U.S. Code, Section 1001.

Check here if comments are provided on back of form. Were latitude and longitude in Section A provided by a licensed land surveyor?  Yes  No

Certifier's Name: WIMAN L. HANIER, Jr. License Number: 2397  
 Title: LAND SURVEYOR, INC Company Name:  
 Address: P.O. Box 92 Richmond Hill City: GA. State: GA. ZIP Code: 31324  
 Signature: [Signature] Date: 1-2-13 Telephone: 912-756-4306



IMPORTANT: In these spaces, copy the corresponding information from Section A.

Building Street Address (including Apt., Unit, Suite, and/or Bldg. No.) or P.O. Route and Box No.

223 VICTOR'S COURT  
City: Richmond Hill

State: GA.

ZIP Code: 31324

For Insurance Company Use:

Policy Number

Company NAIC Number

SECTION D - SURVEYOR, ENGINEER, OR ARCHITECT CERTIFICATION (CONTINUED)

Copy both sides of this Elevation Certificate for (1) community official, (2) insurance agent/company, and (3) building owner.

Comments

Signature

Date

Check here if attachments  
SECTION E - BUILDING ELEVATION INFORMATION (SURVEY NOT REQUIRED) FOR ZONE AO AND ZONE A (WITHOUT BFE)

For Zones AO and A (without BFE), complete Items E1-E5. If the Certificate is intended to support a LOMA or LOMR request, complete Sections A, B, and C. For Items E1-E5, use natural grade, if available. Check the measurement used. In Puerto Rico only, enter meters.

- E1. Provide elevation information for the following and check the appropriate boxes to show whether the elevation is above or below the highest adjacent grade (HAG) and the lowest adjacent grade (LAG).
  - a) Top of bottom floor (including basement, crawlspace, or enclosure) is \_\_\_\_\_  feet  meters  above or  below the HAG
  - b) Top of bottom floor (including basement, crawlspace, or enclosure) is \_\_\_\_\_  feet  meters  above or  below the LAG.
- E2. For Building Diagrams 6-9 with permanent flood openings provided in Section A items 8 and/or 9 (see pages 8-9 of Instructions), the next higher floor (elevation C2.b in the diagrams) of the building is \_\_\_\_\_  feet  meters  above or  below the HAG.
- E3. Attached garage (top of slab) is \_\_\_\_\_  feet  meters  above or  below the HAG.
- E4. Top of platform of machinery and/or equipment servicing the building is \_\_\_\_\_  feet  meters  above or  below the HAG.
- E5. Zone AO only: If no flood depth number is available, is the top of the bottom floor elevated in accordance with the community's floodplain management ordinance?  Yes  No  Unknown. The local official must certify this information in Section G.

SECTION F - PROPERTY OWNER (OR OWNER'S REPRESENTATIVE) CERTIFICATION

The property owner or owner's authorized representative who completes Sections A, B, and E for Zone A (without a FEMA-issued or community-issued BFE) or Zone AO must sign here. The statements in Sections A, B, and E are correct to the best of my knowledge.

Property Owner's or Owner's Authorized Representative's Name

Address

City

State

ZIP Code

Signature

Date

Telephone

Comments

SECTION G - COMMUNITY INFORMATION (OPTIONAL)

The local official who is authorized by law or ordinance to administer the community's floodplain management ordinance can complete Sections A, B, C (or E), and G of this Elevation Certificate. Complete the applicable item(s) and sign below. Check the measurement used in Items G8 and G9.

- G1.  The information in Section C was taken from other documentation that has been signed and sealed by a licensed surveyor, engineer, or architect who is authorized by law to certify elevation information. (Indicate the source and date of the elevation data in the Comments area below.)
- G2.  A community official completed Section E for a building located in Zone A (without a FEMA-issued or community-issued BFE) or Zone AO.
- G3.  The following information (Items G4-G9) is provided for community floodplain management purposes.

G4. Permit Number	G5. Date Permit Issued	G6. Date Certificate Of Compliance/Occupancy Issued
-------------------	------------------------	---

- G7. This permit has been issued for:  New Construction  Substantial Improvement
- G8. Elevation of as-built lowest floor (including basement) of the building \_\_\_\_\_  feet  meters (PS) Datum \_\_\_\_\_
- G9. BFE or (in Zone AO) depth of flooding at the building site \_\_\_\_\_  feet  meters (PS) Datum \_\_\_\_\_
- G10. Community's design flood elevation \_\_\_\_\_  feet  meters (PS) Datum \_\_\_\_\_

Local Official's Name	Title
Community Name	Telephone
Signature	Date
Comments	

Check here if attachments